

Viral Filtration Efficiency (VFE) Final Report

Test Article: i-Life PTFE Face Mask
 Study Number: 892417-S01
 Study Received Date: 12 May 2016
 Test Procedure(s): Standard Test Protocol (STP) Number: STP0007 Rev 13

Summary: The VFE test is performed to determine the filtration efficiency by comparing the upstream viral control counts to downstream test article counts. A suspension of bacteriophage ΦX174 was aerosolized using a nebulizer and delivered to the test article at a constant flow rate and challenge delivery. The challenge delivery is maintained at $1.1 - 3.3 \times 10^3$ plaque forming units (PFU) with a mean particle size (MPS) at $3.0 \mu\text{m} \pm 0.3 \mu\text{m}$. The aerosol droplets were drawn through a six-stage, viable particle, Andersen sampler for collection. This method allows a reproducible challenge to be delivered to the test articles. The VFE test procedure was adapted from ASTM F2101.

All test method acceptance criteria were met. Testing was performed in compliance with US FDA good manufacturing practice (GMP) regulations 21 CFR Parts 210, 211 and 820.

Test Side: Either Side
 Area Tested: $\sim 40 \text{ cm}^2$
 VFE Flow Rate: 28.3 Liters per minute (L/min)
 Conditioning Parameters: $85 \pm 5\%$ relative humidity (RH) and $21 \pm 5^\circ\text{C}$ for a minimum of 4 hours.
 Positive Control Average: 2.0×10^3 PFU
 Negative Monitor Count: <1 PFU
 MPS: $2.9 \mu\text{m}$

Results:

Test Article Number	Percent VFE (%)
1	$>99.9^a$
2	$>99.9^a$
3	$>99.9^a$
4	$>99.9^a$
5	$>99.9^a$

^a There were no detected plaques on any of the Andersen sampler plates for this test article.

The filtration efficiency percentages were calculated using the following equation:

$$\% VFE = \frac{C - T}{C} \times 100$$


C = Positive control average

T = Plate count total recovered downstream of the test article

Note: The plate count total is available upon request



 Technical Reviewer



 Study Director

Trang Truong, B.S.



31 May 2016
 Study Completion Date



892417-S01